



**Hotstream Recommended Installation**

<b>HANDWASH</b>		
<b>REGION</b>	<b>HEATER</b>	<b>TAPWARE</b>
AUCKLAND / NORTH	HS4/1	HS/OS
LOWER NORTH ISLAND	HS4/1 OR HS6/1	HS/OS
CENTRAL NORTH / SOUTH ISLAND	HS6/1, HS7/1 OR HS8/1	HS/OS
<b>BASIN</b>		
NORTHLAND	HS6/1 OR HS8/1	HS/SC
NORTH ISLAND	HS8/1	HS/SC
CENTRAL NORTH / SOUTH ISLAND	HS8/1 OR HS10/2	HS/SC
<b>SHOWER</b>		
NORTHLAND	HS6/1 OR HS8/1	HS/SH
NORTH ISLAND	HS8/1, HS8/2 OR HS10/2	HS/SH
CENTRAL / SOUTH	HS8/1, HS8/2 OR HS10/2	HS/SH
<b>SLIDE SHOWER SET MAY BE USED FOR LOW PRESSURE APPLICATIONS</b>		
<b>HAIRDRESSER</b>		
NORTHLAND	HS6/1, HS7/1, HS8/1, HS8/1H	HS/H
ALL OTHERS	HS8/1H OR HS8/2	HS/H

**Comments –**

- **Inlet pressure – MINIMUM 35 psi, MAXIMUM 100 psi**
- **Because of surges and pressure fluctuations, a supply of 100 psi can cause leaks.**
- **Therefore the recommended installation is a 500 kpa (70psi) pressure limiting valve where the inlet pressure is over 70 psi.**



**I N S A P I P E I N D U S T R I E S L T D**

**20A Arwen Place East Tamaki, PO Box 258-042 Greenmount, Auckland Ph – 09 273 3703, Fax – 09 273 3704**